

(R)



# HYGIENE WATERWAVE ENGINEERING CO.

AN ISO 9001: 2015 CERTIFIED COMPANY

Best Quality Water Treatment & Service Organization



## TEST REPORT


Name : Church Bell School

Add : T..N Mukherjee Road, Raghunathpur,  
Makhla, Hooghly - 712247

### Analytical Report of Raw Water

Report No. : WT/06-24	Date of report : 27-03-2024
Sample drawn by : S.K. Mitra	Page : 1
Sample Collection on : 13-03-2024	Source : Raw Water

Sl No.	Parameters	Result Filter Water	IS : 10500-1991 Drinking Water Specification (Amendment No. 3, July, 2010)	
			Highest Desirable Limit	Max. Permissible limit(In absence of Alternative Source)
1	Total Hardness (as CaCO <sub>3</sub> )	550 PPM	300 PPM	600 PPM
2	Total Iron (as Fe)	1.5 PPM	0.3 PPM	1.0 PPM
3	Turbidity	8 NTU	5 NTU	10 NTU
4	Total Dissolved Solids	1160 PPM	500 PPM	2000 PPM



Checked by

For HYGIENE WATERWAVE ENGINEERING CO.

Attested  
For CHURCH BELL SCHOOL  
Meena Mitra  
Principal